



Nashua Fire Rescue

Fire Marshal's Office

177 Lake Street, Nashua NH 03060-4402
NashuaNH.gov

Adam Pouliot
Fire Marshal
(603) 589-3460
Fax (603) 589-3474

Food Truck/Trailer Inspection

- Current DMV registration and state inspection sticker
- Wheel chocks shall be used to prevent mobile and temporary cooking units from moving. (NFPA 1 2018, 50.7.1.3)

Fuel type for cooking

- LPG
- Electric
- LPG fuel supply to the cooking equipment shall be NFPA 58 compliant and is the sole responsibility of the applicant to have said system installed and maintained by a licensed gas fitter.

“LP-Gas systems on mobile food service vehicles shall be certified for compliance with NFPA 58 by an approved company with expertise in the installation, inspection, and maintenance of LP-Gas systems. (NFPA 1 2018, 50.7.2.3.4)”

Cooking equipment

- Layout under the hood
- Baffle between deep fat fryers and open flames (minimum 8” in height measured from the higher of the two)
- Cover for the deep fat fryer

Hood System

- Grease laden vapor requires type 1 hood and duct work (Valid hood inspection sticker)
- UL 300 system for the hood suppression (6 Month inspection)
- K type fire extinguisher (Annual inspection)
- 2A:10BC fire extinguisher minimum (Annual inspection)

Applicant: _____
Business Name

Signature: _____

Date: _____

Inspector: _____

Date: _____