



Nashua Fire Rescue

Fire Marshal's Office

177 Lake Street, Nashua NH 03060-4402
NashuaNH.gov

Adam Pouliot
Fire Marshal
(603) 589-3460
Fax (603) 589-3474

Dry Chemical Suppression System Plan Requirements

Complete plan submittals required for review/approval; all others will be returned
Each box must be checked off for acknowledgment

- Location information
- Applicant information
- Cut sheets submitted
- Equipment layout (sketch: layout of system and equipment)
- How many flows is this system designed for? _____
- How many flows is this system using? _____
- Sequence of operation indicated on plans:
 - Tied into the building fire alarm system. Yes ____ No ____ If no fire alarm is on site local horn/strobes shall be installed.
 - Power disengaged

If the system is protecting a Motor Fuel Dispensing Facility then activation of the automatic fire suppression system will automatically transmit an alarm to an alarm receiving point approved by the local fire official. (NH Saf-C 6009.03)

System shall pass pretest 100% prior to scheduling an inspection.

Acceptance test will be required upon completion of install. Failed test will require a re-inspection and a **\$150.00 re-inspection fee** (Reference O-22-023) to be paid prior to scheduling the next inspection.

Check with building department for their requirements.

- Mechanical inspector
- Plumbing inspector
- Electrical inspector

Applicant Signature

Date

Office use: Permit # _____

- Revisions required
- Plans approved